

Exova Warringtonfire Aus Pty Ltd
 Unit 2, 409-411 Hammond Road
 Dandenong, Victoria 3175
 Australia

T: +61 (0)3 9767 1066
 F: +61 (0)3 9767 1001
 E: market.pacific@exova.com
 W: www.exova.com



Postal Address:
 PO Box 4282
 Dandenong South, Victoria 3164
 Australia

Testing. Advising. Assuring.

EWFA CERTIFICATE OF TEST	CERTIFICATE No : SFC 31154800.2	Page 1 of 1
---------------------------------	--	--------------------

Report Sponsor	Certificate Issue Date
Velux Australia Pty Ltd 78 Henderson Road Alexandria, NSW, 2015	20 January 2015

Introduction

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

Referenced Report	Test Date	Test Standard
EWFA 31154800.1	6 October 2014	AS1530.8.1- 2007



Description of Product		
Product name	Test Specimen Arrangement	Rating
Velux VSS S06 Skylight system with EDW S06 0000 flashing	The system was nominally 1130mm x 1175mm in size and was supported by a timber truss roof clad with corrugated steel roof sheeting. The fascia and gutter were steel. Refer to the test report for a full description.	BAL-40

Notes

THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
Phone / Fax	+61 (0) 3 9767 1000 / +61 (0) 3 9767 1001	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By:  Mandeep Kamal	Reviewed By:  Steven Halliday