

Exova Warringtonfire Aus Pty Ltd  
 Unit 2, 409-411 Hammond Road  
 Dandenong, Victoria 3175  
 Australia

T: +61 (0)3 9767 1066  
 F: +61 (0)3 9767 1001  
 E: market.pacific@exova.com  
 W: www.exova.com



Postal Address:  
 PO Box 4282  
 Dandenong South, Victoria 3164  
 Australia

Testing. Advising. Assuring.

<b>EWFA CERTIFICATE OF TEST</b>	<b>CERTIFICATE No.: SFC 34505800.1</b>	<b>Page 1 of 1</b>
---------------------------------	--	--------------------

Report Sponsor	Certificate Issue Date
Velux Australia Pty Ltd 78 Henderson Road Alexandria, NSW, 2015	1 June 2015

**Introduction**

The element of construction described below was tested by this laboratory on behalf of the test sponsor in accordance with the stated test standard and achieved the results stated below. Refer to the referenced test report for more information.

Referenced Report	Test Date	Test Standard
EWFA 34505800.1	13 March 2015	AS1530.8.1- 2007



Description of Product		
Product name	Test Specimen Arrangement	Rating
Velux TWR 0K14 2010 Sun Tunnel	The system was nominally 460mm x 460mm in size and was supported by a timber truss roof clad with corrugated steel roof sheeting. The fascia and gutter were steel. The specimen was tested at a BAL 29 exposure level with no cribs.  Refer to the test report for a full description.	<b>BAL-29</b>

**Notes**

**THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE.**

Reference should be made to the relevant test report to determine the applicability of the test result to a proposed installation and for a full description of the tested construction.

The results of these fire tests may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.

<b>TESTING AUTHORITY</b>	Exova Warringtonfire Aus Pty Ltd	
<b>Address</b>	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road, DANDENONG VIC 3175	
<b>Phone / Fax</b>	+61 (0) 3 9767 1000 / +61 (0) 3 9767 1001	
<b>ABN</b>	81 050 241 524	
<b>Email / Home Page</b>	<a href="http://www.exova.com">www.exova.com</a>	
<b>Authorisation</b>	Prepared By:   Mandeep Kamal	Reviewed By:   Steven Halliday