



IAN BENNIE & ASSOCIATES PTY. LTD.



Registered Laboratory No. 2371

TEST CERTIFICATE No. 2015-014-S5

Test Client	Certificate Issue Date
VELUX Australia Pty Ltd 321-323 Princes Highway St.Peters NSW 2044	7 September, 2015

Introduction
The roof window described below was tested by this laboratory on behalf of the test client in accordance with the nominated subclauses of the stated standard and achieved the results shown below. Refer to the referenced test report(s) for full sample details and compliance information.

Product Name	Test Standard	Test Date
VSS S06 2004A	AS 4285-2007 (refer below for test clauses)	7 September, 2015

IBA Report	Description of product
2015-014-S5	The system was nominally 1157mm x 1200mm OD secured to a metal base and with an EDW flashing kit. Installation was in accordance with VELUX VS installation instructions VAS 452262-0509 and EDW instructions VAS 452198-0209. Glazing 3mm toughened outer/12 Argon/2.5HS-0.76-2.5HS laminated inner
3.2.2.5: Watertightness	Result: Pass at 27° roof pitch (default)

NOTES
THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE
Reference should be made to the relevant test report(s) to determine the applicability of the test result to a proposed installation.

TEST LABORATORY	IAN BENNIE and ASSOCIATES Pty Ltd	ACN: 007 133 253
Address:	1 Luisa Avenue, Dandenong, VIC 3175	
Phone / Fax:	03 9768-3640 / 03 9768-3642	
Prepared by:	VELUX Australia Pty Ltd	

This certificate provided by VELUX Australia. Full test report available on application.