



Certificate of Conformity

Certification Body:



Global-Mark Pty Ltd,
Suite 4.07, 32 Delhi
Road, North Ryde
NSW 2113, Australia

Tel: +61 (0)2 9886
0222 - www.Global-Mark.com.au

Certificate Holder:
Velux Australia Pty
Ltd
78 Henderson Road
Alexandria NSW 2015
Australia
Tel: 1300 859 856
www.velux.com.au

Certificate number: CM 30091 Rev4

THIS TO CERTIFY THAT

Velux Sun Tunnels TWR & TWF

Type and/or use of product:

Velux sun tunnels are used to bring natural light into attics or loft rooms where daylight is required.

Velux sun tunnels are designed for use with all building types, subject to limitations detailed within this certificate and technical documentation

Description of product:

Velux TWR Sun Tunnels provide daylight using a rigid tube from the roof surface to the internal ceiling lining.

Velux TWF Sun Tunnels provide daylight using a flexible tube from the roof surface to the internal ceiling lining.

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2019 + A1

	Volume One – Amendment 1		Volume Two – Amendment 1	
Performance Requirement(s)	FP1.4	Health & Amenity - Weatherproofing	P2.2.2	Weatherproofing
Deemed-to-Satisfy Provision(s):	B1.4 (h) (ii)	Structure	3.6.0 (b) (iv)	Structure – Glazing
	F4.2	Health & Amenity – Natural Light	3.8.4.2	Natural Light
	F4.3	Health & Amenity – Natural Light borrowed from adjoining room		
	G5.2	Construction in Bushfire Prone Areas	3.10.5.0 (c)	Bushfire Areas
State or territory variation(s):	NSW G5.2	Construction in Bushfire Prone Areas	NSW 3.10.5.0	Bushfire Areas

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the certificate holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

The purpose of Global-Mark **construction site audits** is to confirm the practicability of installing the product; and to confirm the appropriateness and accuracy of installation instructions. In placing the **CodeMark mark** on the product/system, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the **expertise of external bodies** (laboratories, and technical experts).

Herve Michoux
Global-Mark Managing Director

Peter Gardner
Unrestricted Building Certifier

Date of issue: 12/12/2021

Date of expiry: 06/08/2024



Certificate of Conformity

QLD 3.10.5.0

Bushfire Areas

SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B

Limitations and conditions:	Building classification/s:
<p>Volume 1 and Volume 2 – Schedule 3 – Definitions: Sun Tunnels are to be installed at an angle greater than 15 degrees measured from the horizontal plane.</p>	<p>All Building Types</p>
<p>Volume 1 BP1.1 Sun Tunnels are to be specified only for non-cyclonic wind regions and have maximum Ultimate Limit State Wind Loads of +5.0kPa & -7.0kPa.</p>	<p>2, 3, 4, 5, 6, 7, 8 & 9</p>
<p>Volume 2 - 3.6.1 – Structure - Glazing (Condition / Limitation – limited to N3 Wind): Sun Tunnels are to be specified only for non-cyclonic wind regions and have maximum Ultimate Limit State Wind Loads of +5.0kPa & -7.0kPa.</p>	<p>1 & 10</p>
<p>Volume 2 - 3.6.3 – Sizes of Glazing Panes Minimum thickness of glazing as nominated within design tables included within Part 3.6.3 of Vol 2, and/or glass design to adhere to AS1288.</p>	<p>1 & 10</p>
<p>Volume 1 - Spec C1.1 – 3.6 If a roof is <i>required</i> to have an FRL or its covering is <i>required</i> to be <i>non-combustible</i>, rooflights or the like installed in the roof must: (a) have an aggregate area of not more than 20% of the roof surface; and (b) be not less than 3 m from— (i) any boundary of the allotment other than the boundary with a road or public place; and (ii) any part of the building which projects above the roof unless that part has the FRL required of a fire wall and any openings in that part of the wall for 6 m vertically above the rooflight or the like are protected in accordance with C3.4; and (iii) any rooflight or the like in an adjoining sole-occupancy unit if the walls bounding the unit are required to have an FRL; and (iv) any rooflight or the like in an adjoining fire-separated section of the building; and (c) if a ceiling with a resistance to the incipient spread of fire is required, be installed in a way that will maintain the level of protection provided by the ceiling to the roof space.</p>	<p>2, 3, 4, 5, 6, 7, 8 & 9</p>



Certificate of Conformity

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

See page 1 of this certificate: Type and/or use of product

A2 Description of product

See page 1 of this certificate: Description of product

- Velux Sun Tunnels must be installed in orientations greater than 15 degrees when measured from the horizontal plane.
- Velux Sun Tunnels are available in a single size, as described in Item 1 as listed in Appendix B2.

A3 Product specification

Refer to document 001 as listed in Appendix B2, “Aust New Sun Tunnel Product sheet 2017 web” dated November 2017.

A4 Manufacturer and manufacturing plant(s)

Velux Australia Pty Ltd
78 Henderson Road
Alexandria NSW 2015
Australia

Partizánske Building Components-SK s.r.o.
Malobielická 1/215
958 04 Partizánske
SLOVAKIA

A5 Installation requirements

Refer to Velux product installation instructions for TWF Sun Tunnels, document reference – “V2.0 TWF - TLF SUNTUNNEL Flexible - 453842-2015-01”.

Refer to Velux product installation instructions for TWR Sun Tunnels, document reference – “V2.0 TWR-TLR SUNTUNNEL Rigid - 453834-2015-01”.

A6 Other relevant technical data

Any referenced documents within the technical literature identified in Appendix A, A3 and Appendix A, A5.

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

The following assessment methods have been used to determine compliance with NCC 2019:

Code Clause	Assessment Method(s)	Evidence of suitability	Evidence reference in B2
NCC Volume One FP1.4	A2.2 (2) (a) & (b)	A5.2 (1) (d)	Items 5 & 6
NCC Volume Two P2.2.2	A2.2 (2) (a) & (b)	A5.2 (1) (d)	Items 5 & 6
NCC Volume One B1.4 (h) (ii)	A2.3 (2) (a)	A5.2 (1) (d)	Items 5 & 6
NCC Volume Two 3.6.0 (b) (iv)	A2.3 (2) (a)	A5.2 (1) (d)	Items 5 & 6
NCC Volume One F4.2	A2.3 (2) (a)	A5.2 (1) (f)	Items 1 & 2
NCC Volume One F4.3	A2.3 (2) (a)	A5.2 (1) (f)	Items 1 & 2
NCC Volume Two 3.8.4.2	A2.3 (2) (a)	A5.2 (1) (f)	Items 1 & 2
NCC Volume One G5.2	A2.3 (2) (a)	A5.2 (1) (d)	Items 3 & 4
NCC Volume Two 3.10.5.0 (c)	A2.3 (2) (a)	A5.2 (1) (d)	Items 3 & 4

B2 Reports

The following reports have been used as evidence to determine compliance with NCC 2019:

Ref	Author	Reference	Date	Description	NATA Registration
1	Velux Australia Pty Ltd	Aust New Sun Tunnel Product sheet 2018 web	Jan 18	Product brochure and data sheet for Velux Sun Tunnels TWF & TWR	–
2	Velux Australia Pty Ltd	Declaration of Performance TWR OK14 2010E 2014	9-Mar-11	CE Product declaration data for TWR & TWF Sun Tunnels	–
3	Exova Warringtonfire	2686103.1	06-Jul-12	Fire Test Report	3277
4	Exova Warringtonfire	34505800.1	12-May-15	Fire Test Report	3277
5	Ian Bennie & Associates	4023S12-TWF	11-May-05	Weathertightness & Structural Test Report	2371
6	Ian Bennie & Associates	2015-014-S1 - TWR TWF V2.0	17-Sep-15	Weathertightness & Structural Test Report	2371

The Certificate Holder has chosen not to make the above identified evidence of compliance publicly available, due to the documents being considered commercial in confidence.

End of Certificate