



**IAN BENNIE & ASSOCIATES PTY. LTD.**



**TEST CERTIFICATE No. 2014-067-C1**

Test Client	Certificate Issue Date
VELUX Australia Pty Ltd 321-323 Princes Highway St.Peters NSW 2044	9 October 2014

Introduction
The roof window described below was tested by this laboratory on behalf of the test client in accordance with the nominated subclauses of the stated standard and achieved the results shown below. Refer to the referenced test report(s) for full sample details and compliance information.

Product Name	Test Standard	Test Date
GGL-SK06-3076	AS 4285-2007 (refer below for test clauses)	8-9 October 2014

IBA Report	Description of product
2014-067-S1 and S3	The system was nominally 1140mm x 1180 OD with an EDW-SK06 flashing kit for the water penetration test.  Glazing 4mm toughened outer/14 Argon/6.38 laminated inner
3.2.2.5: <b>Watertightness</b>	Result: <b>Pass at default 27° roof pitch only (Report 2014-067-S1)</b>
3.2.2.2: <b>Concentrated load</b>	Result: <b>Pass (Report 2014-067-S1)</b>
3.2.2.3: <b>Non-cyclonic pressure</b>	Result: <b>Pass at +4 / -6 kPa (Report 2014-067-S1)</b>
3.2.2.4: <b>Cyclonic pressure</b>	Result: <b>Pass at +4.0 kPa (Report 2014-067-S3)</b>

NOTES
<b>THIS CERTIFICATE IS PROVIDED FOR GENERAL INFORMATION ONLY AND DOES NOT COMPLY WITH THE REGULATORY REQUIREMENTS FOR EVIDENCE OF COMPLIANCE</b>
Reference should be made to the relevant test report(s) to determine the applicability of the test result to a proposed installation.

<b>TEST LABORATORY</b>	IAN BENNIE and ASSOCIATES Pty Ltd	ACN: 007 133 253
Address:	1 Luisa Avenue, Dandenong, VIC 3175	
Phone / Fax:	03 9768-3640 / 03 9768-3642	
Prepared by:	Ian Bennie	