

Certificate of Compliance – Design (Form 15)

I certify that the items described below, installed, or carried out in accordance with the information contained in this certificate, including any referenced documentation, will comply with the requirements of the building regulations as given below.

1. Property Description

No Specific property is specified. However, for this certificate to be applicable, the design wind pressures for the Skylights and Roof Windows in building on the property shall be within the pressures given in Tables 13 to 18 of the Calderone and Associates Report, dated 16 July 2017.

2. Description of the components certified

Velux IGU Skylight and Roof Window models, having glass supported on all 4 edges having sizes and glass types and combinations as detailed in Section 2 of the Calderone and Associates Report, dated 16 July 2017. The models are:

- Fixed Skylight Model FS 2004.
- Ventilating Skylight Model VS/VSE/VSS 2004
- Fixed Curb Mounted Skylight Model FCM 0004
- Ventilating Curb Electric Skylight Model VCE 2004
- Ventilating Curb Manual Skylight Model VCM 2004
- Ventilating Curb Solar Skylight Model VCS 2004
- Roof Window Model GGL/GHL/GPL 3076 – V21
- Roof Window Model GGL/GPL 3076 – V22
- Roof Window Model GGL/GPL 2076 – V22

3. Basis of Certification

I certify that the items described above comply with the following provisions of the building Regulations.

AS1288 when the outer and inner glass components of the Insulating Glass Units are manufactured in accordance with the requirements of AS/NZS 2208.

4. Referenced Documents

Calderone and Associates Report, regarding “Skylight Glass Design for VELUX Australia Pty Ltd” dated 16 July 2017.

5. Certifier reference number

Registered Building Practitioner EM1105.

6. Name and details

Dr. Ignatius Calderone
Calderone and Associates Pty Ltd
Tel : 03 9741 1825
Mobile Tel: 0409 136 353
Email: icalder1@bigpond.net.au

7. Signature



Dr. Ignatius Calderone
PhD MEng Sc BE(Mech), MIE(Aust) # 320848, CPEng, NPER,
Registered Building Practitioner EM1105
Director, Calderone and Associates Pty Ltd.